

# CLASSIFICATION REPORT SIDE HINGED STEEL DOOR

<b>Name of sponsor:</b>	Door System A/S		
<b>Product name:</b>	MH075		
<b>File:</b>	PCA10434A	<b>Revision:</b>	5
<b>Date:</b>	2024-11-01		
<b>Pages:</b>	9	<b>Enclosures:</b>	4
<b>Ref:</b>	LSK / RBI		

---

## Classification

### Reference

This classification has been carried out in accordance with clause 7.5.5 of EN 13501-2:2023.

### Classification

The product is classified according to the following combinations of performance and classes as appropriate.

**Fire resistance classification:** EI<sub>2</sub> 60-C\*

\* Depending on the use of door hardware, the door may be classified with or without the self-closing classification C.

The classification is valid for fire resistance from either side.