

CLASSIFICATION REPORT SINGLE LEAF STEEL SLIDING DOOR

Name of sponsor: Door System A/S

Product name: MS071/AS071

File no.: PCA10625A Revision no.: 3

Date: 2024-03-05

Pages: 21 Encl.: 0

Ref: LSK / TDJ

Classification

Reference

This classification has been carried out in accordance with clause 7.5.5 of EN 13501-2.

Classification

The product is classified according to the following combinations of performance and classes as appropriate.

Fire resistance classification: EI₁ 30-C

EI₂ 60-C / EW 60-C

The classification is valid for fire resistance from either side.